

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7270-1597:102

Page 1 of 1

CATEGORY: Heat Detector

LISTEE: TEPG - US, 91 Technology Drive, Westminster, MA 01441-0001
Contact: Paul Mattern (978) 731-8542 FAX (978) 731-8881

DESIGN: Models 430633 and *T360-9350 electric combination rate compensated, fixed temperature, and rate of rise heat detector. Unit intended for use with Models 430637, 430638 or 430636 detector bases (CSFM Listing No. 7300-1597:103). Refer to listee's printed data sheet for additional detailed product description and operational considerations.

RATING: 135°F and 155°F

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical/temperature ratings, and UL label.

APPROVAL: Listed as a heat detector for use with separately listed Ansul Model Autopulse Z-28 (430532) & (430539) (CSFM Listing No. 7170-0595:114) and Pyro-Chem Model Triton RPA (551454) & (551461) (CSFM Listing No. 7170-1565:104) fire alarm control units. Refer to listee's Installation Instruction Manual for details

XLf: 7270-0026-216

*Rev. 05-11-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

MAY 11, 2004

*Listing Expires **June 30, 2004***

Authorized By:

**DIANE K. AREND, Senior Deputy
Program Manager**